

Taylor County
Rural Electric Cooperative
Corporation

P. O. BOX 100

CAMPBELLSVILLE, KENTUCKY 42719

(270) 465-4101 • Fax (270) 789-3625
(800) 931-4551

February 7, 2012

Jeff Derouen, Executive Director
Public Service Commission
211 Sower Blvd
Frankfort, KY 40602

RECEIVED

FEB 08 2012


PUBLIC SERVICE
COMMISSION

Dear Mr. Derouen:

Enclosed are an original and ten copies of Taylor County Rural Electric Cooperative Corporation's Responses to PSC Administrative Case No. 2011-00450.

Sincerely,

TAYLOR COUNTY RURAL ELECTRIC
COOPERATIVE CORPORATION



Mike Skaggs, PE
Engineering/Operations Manager

MS:pwr

TAYLOR COUNTY RECC

RECEIVED

FEB 08 2012

PUBLIC SERVICE
COMMISSION

Responses To:
KY PSC ADMINISTRATIVE CASE NO. 2011-00450

By:
Mike Skaggs, PE
Engineering/Operations Manager

February 6, 2012

ITEM 1

TAYLOR COUNTY RECC
P.O. BOX 100
CAMPBELLSVILLE, KY 42719

RESPONSE TO PSC ORDER IN CASE NO 2011-00450

ITEM 1

- a. 64
- b. Yes
- c. No other indicators or measures are utilized or maintained.

Witness available: Mike Skaggs

ITEM 2

TAYLOR COUNTY RECC
P.O. BOX 100
CAMPBELLSVILLE, KY 42719

RESPONSE TO PSC ORDER IN CASE NO 2011-00450

ITEM 2

- a. Manually via Excel spreadsheet
- b. n/a
- c. SAIDI, SAIFI and CAIDI are tracked on an annual basis. No inquiries have been made concerning the internal development or purchase via a third party vendor of an electronic or mechanized outage tracking system.

Witness Available: Mike Skaggs

ITEM 3

TAYLOR COUNTY RECC
P.O. BOX 100
CAMPBELLSVILLE, KY 42719

RESPONSE TO PSC ORDER IN CASE NO 2011-00450

ITEM 3

- a. Standard is followed
- b. Annually
- c. Annually
- d. None
- e. No

Witness Available: Mike Skaggs

ITEM 4

TAYLOR COUNTY RECC
P.O. BOX 100
CAMPBELLSVILLE, KY 42719

RESPONSE TO PSC ORDER IN CASE NO 2011-00450

ITEM 4

- a. n/a
- b. No
- c. None

Witness Available: Mike Skaggs

ITEM 5

TAYLOR COUNTY RECC
P.O. BOX 100
CAMPBELLSVILLE, KY 42719

RESPONSE TO PSC ORDER IN CASE NO 2011-00450

ITEM 5

- a. The worst performing circuits are generally identified as such due to outages related to forces outside of utility control – in the vast majority of cases weather is the issue although there can be a catastrophic equipment failure that can affect the numbers. Work begins to rectify these outages immediately.
- b. See a. above.

Witness Available: Mike Skaggs