



Steven L. Beshear
Governor

Leonard K. Peters
Secretary
Energy and Environment Cabinet

Commonwealth of Kentucky
Public Service Commission
211 Sower Blvd.
P.O. Box 615
Frankfort, Kentucky 40602-0615
Telephone: (502) 564-3940
Fax: (502) 564-3460
psc.ky.gov

David L. Armstrong
Chairman

James W. Gardner
Vice Chairman

Linda K. Breathitt
Commissioner

June 6, 2012

Mr. Kenneth Taylor
Kenvirons, Inc.
452 Versailles Road
Frankfort, Kentucky 40602

Re: Case No. 2012-00045
Whitley County Water District

Dear Mr. Taylor:

The enclosed document has been filed in the record of the above-referenced case. Any objections to this action should be submitted to the Commission within five days of receipt of this letter.

Sincerely,

A handwritten signature in black ink, appearing to read "Jeff Derouen".

Jeff Derouen
Executive Director

gw
Enclosure



STEVEN L. BESHEAR
GOVERNOR

LEONARD K. PETERS
SECRETARY

ENERGY AND ENVIRONMENT CABINET
DEPARTMENT FOR ENVIRONMENTAL PROTECTION
DIVISION OF WATER
200 FAIR OAKS LANE, 4TH FLOOR
FRANKFORT, KENTUCKY 40601
www.kentucky.gov

February 13, 2012

Mr. Albert Mahan
Whitley Co Water District No 1
19 US 25W South
Williamsburg, KY 40769

RE: Whitley Co Water District No 1
AI # 34133, APE20120001
PWSID # 1180468-12-001
Pleasant Ridge Road WLE Permit
Whitley County, KY

Dear Mr. Mahan:

We have reviewed the plans and specifications for the above referenced project. The plans include the construction of approximately 440 LF of 2-inch WLE. This is to advise that plans and specifications for the above referenced project are APPROVED with respect to sanitary features of design, as of this date with the requirements contained in the attached construction permit with condition that no additional line extensions will be made to this line unless the two inch line size increased.

If you have any questions concerning this project, please contact Mr. Abbas Pourghasemi at 502-564-3410 x4833.

Sincerely,

Mark Rasche, P.E.
Supervisor, Engineering Section
Water Infrastructure Branch
Division of Water

MER: AGP

Enclosures

C: Kenvirons, Inc.
Whitley County Health Department
Public Service Commission
Division of Plumbing