RECEIVED

COMMONWEALTH OF KENTUCKY BEFORE THE PUBLIC SERVICE COMMISSION

MAY 06 2015

In the Matter of:

PUBLIC SERVICE
COMMISSION

APPLICATION OF BULLITT UTILITIES, INC.)	CASE NO 2014-00255
FOR A CERTIFICATE OF CONVENIENCE AND)	
NECESSITY AND SURCHARGE FOR SAME)	

NOTICE OF FILING BY BULLITT UTILITIES, INC.

Comes Bullitt Utilities, Inc. ("Bullitt Utilities"), by counsel, and hereby files the signature page to its First Supplement to the Answers of Bullitt Utilities to the Attorney General's Second Request for Information, which has been executed by Chris Cogan, as the Attorney-in-Fact of Carroll F. Cogan, the President of Bullitt Utilities, Inc. The First Supplement to the Answers of Bullitt Utilities to the Attorney General's Second Request for Information were filed with the Commission on May 1, 2015.

Respectfully submitted,

Robert C. Moore

HAZELRIGG & COX, LLP

415 West Main Street, 1st Floor

P. O. Box 676

Frankfort, Kentucky 40602-0676

(502) 227-2271

Email: Rmoore@Hazelcox.com

CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of the foregoing was served by hand delivery on Jeff Derouen, Executive Director, Public Service Commission, 211 Sower Blvd., P.O. Box 615, Frankfort, Kentucky 40602 and by United States Mail on Gregory T. Dutton and Jennifer Black Hans, Assistant Attorney General, 1024 Capital Center Drive, Suite 200, Frankfort, Kentucky 40601-8204, on this the Art day of May, 2015.

Robert C. Moore

the timeframe from March 29, 2013, to March 29, 2015, to address inflow and infiltration (I & I) into the Hunters Hollow collection system (hereinafter "Collection System"), which has a direct connection to any back-ups that may have occurred in the Collection System: 1) a video inspection of the Collection System was performed by Pipe Eyes, LLC at a cost of \$36,900.93. The sewer lines in the Collection System were cleaned by jetting prior to the video survey; 2) During periods of heavy rain when the lift station duplex pumps were unable to keep up with the flow in the Collection System, a third pump was used to pump water from the two lift stations in the Collection System; and 3) BlueStone Engineers was engaged to review the results of the video survey of the Collection System prepared by Pipe Eyes, LLC, prepare a Sanitary Sewer Evaluation Study ("SSES") for Bullitt Utilities, and conduct an inspection of the manholes on the Collection System for the amount of \$10,540. The SSES was submitted to the Kentucky Department of Environmental Protection ("DEP"), and is currently being updated at its request.

Witnesses: Chris Cogan and Lawrence Smither.

Information Request No. 3: Provide a table showing the date and amount of each bypass for one year immediately prior to and one year immediately following the facility failure.

Answer: Objection. Bullitt Utilities objects to this request on the basis that it seeks information that is irrelevant to the application for surcharge case filed by Bullitt Utilities.

Without waiving this objection, Bullitt Utilities states, see Answers of Bullitt Utilities to the Information Requests of the Public Service Commission in PSC Case No. 20 14–00163, tab two, and for information concerning bypasses occurring after May 2014, See Attachment 2.

STATE OF FLORIDA

Chris Cogan

COUNTY OF Franklin

My commission expires: 3-11-18

Notary Public

Respectfully submitted,

Robert C. Moore

HAZELRIGG & COX, LLP

415 West Main Street, 1st Floor

P.O. Box 676

Frankfort, Kentucky 40602-0676

(502) 227-2271

CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of the foregoing was served by hand delivery on Jeff Derouen, Executive Director, Public Service Commission, 211 Sower Blvd., P.O. Box 615, Frankfort, Kentucky 40602 and by United States Mail on Gregory T. Dutton and Jennifer Black Hans, Assistant Attorney General, 1024 Capital Center Drive, Suite 200, Frankfort, Kentucky 40601-8204, on this the / day of May, 2015.

Robert C. Moore