

Beech Grove Water System, Inc.

445 Highway 56 N

Calhoun KY 42327

[beechgrovewaters@bellsouth.net](mailto:beechgrovewaters@bellsouth.net)

RECEIVED

NOV 4 2014

PUBLIC SERVICE  
COMMISSION

**Executive Director**

Mr. Jeff Derouen  
Public Service Commission  
PO Box 615  
Frankfort, KY 40602

RE: Case No. 2014-00306

Application of Beech Grove Water System, Inc.  
Requesting Deviation From Requirements of  
807 KAR 5:066. Section 4 (4)

Dear Mr. Derouen:

Enclosed for filing on Beech Grove Water System there are the original and ten (10) copies of the Applicant's Response to Commission Staff's First Information Request.

Should you need any additional information, please let me know.

Sincerely



Shirley Cheatham  
Secretary- Treasurer

Prepared by  
Sheila Murphy

**COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION**

IN THE MATTER OF:

THE APPLICATION OF  
BEECH GROVE WATER SYSTEM  
Requesting Deviation from Requirements of  
807 KAR 5:066. Section 4 (4)

CASE NO.  
2014-00306

\*\*\*\*\*  
**CERTIFICATION OF RESPONSE TO COMMISSION  
STAFF'S FIRST INFORMATION REQUEST**  
\*\*\*\*\*

This is to certify that I have supervised the preparation of the Applicant's Response to the Commission Staffs First Information Request. The responses submitted on behalf of Beech Grove Water System are true and accurate to the best of my knowledge, information, and belief formed after a reasonable Inquiry.

Date: 10-30-2014



Shirley Cheatham  
Secretary - Treasurer

Prepared By  
Sheila Murphy

In the Matter of:

APPLICATION OF BEECH GROVE WATER  
SYSTEM, INC. REQUESTING DEVIATION FROM  
REQUIREMENTS OF 807 KAR 5:066, SECTION 4  
(4)

CASE NO.2014-00306

COMMISSION STAFF'S FIRST REQUEST FOR INFORMATION  
TO BEECH GROVE WATER SYSTEM, INC.

We are sorry that we still do not have an answer for the following two (2) questions. We have Randall Kelley with Kentucky Rural Water Association schedule to be here November 20, 2014 to help us provide the correct pressure and elevations for the water system.

1d . Provide a representation of the ground elevation of the area served by the tank. Explain any difference in the elevation of the Tank and the service territory of the customers served by the Tank.

2. Indicate the effective storage of the Beech Grove Tank in gallons, taking

Into account the minimum pressure requirement of 30 pounds per square inch pursuant to 807 KAR 5:066, Section 5. Explain the impact to effective storage caused by any difference in elevation between the Tank and the service territory of the Beech Grove customers served by the tank.

Again, I am sorry for the inconvenience to you. We are asking for another extension until November 28, 2014.

Sincerely,

Shirley Cheatman