

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF HIMA-SIBERT WATER )  
DISTRICT FOR A DEVIATION FROM 807 KAR )  
5:066, SECTION 5(4) REGARDING WATER ) CASE NO. 10484  
STORAGE )

O R D E R

By letter received November 21, 1988, Hima-Sibert Water District ("Hima-Sibert") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a utility to provide water storage to insure a minimum of one day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. Hima-Sibert has no water storage tanks in its water distribution system.

2. Hima-Sibert's average daily water usage including unaccounted-for-water is 66,000 gallons.

3. Hima-Sibert has applied for funds from Farmers Home Administration and Appalachian Regional Commission to build a 100,000-gallon storage tank.

4. Because of the time needed to plan, finance and implement a program to construct water storage facilities, Hima-Sibert should be granted a deviation from 807 KAR 5:066, Section 5(4) until February 1, 1992 to bring it within compliance of the Commission's water storage requirements.

IT IS THEREFORE ORDERED that:


1. Hima-Sibert be and it hereby is granted a deviation from 807 KAR 5:066, Section 5(4) until February 1, 1992.


2. Hima-Sibert shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to the expiration date of the deviation herein granted.

Done at Frankfort, Kentucky, this 13th day of January, 1989.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

\_\_\_\_\_  
Executive Director