

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WEST MCCRACKEN)
COUNTY WATER DISTRICT FOR A DEVIATION) CASE NO. 90-272
FROM 807 KAR 5:066, SECTION 9(2))
REGARDING DEAD END LINES)

O R D E R


By letter received September 4, 1990, West McCracken County Water District ("West McCracken") requested a three year time period to bring its facilities into compliance with 807 KAR 5:066, Section 9(2). This regulation requires a water utility to provide blow-off valves for the purpose of flushing dead-end water mains.


The Commission, having reviewed the application and being otherwise sufficiently advised, finds that West McCracken should be allowed additional time to comply with 807 KAR 5:066, Section 9(2).


IT IS THEREFORE ORDERED that West McCracken be and it hereby is given until October 1, 1993 to comply with the provisions of 807 KAR 5:066, Section 9(2).


Done at Frankfort, Kentucky, this 20th day of September, 1990.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner


Executive Director