

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF OLDHAM COUNTY WATER)	CASE NO.
DISTRICT FOR A DEVIATION FROM THE)	2005-00340
REQUIREMENTS OF 807 KAR 5:066, SECTION)	
4(4), REGARDING WATER STORAGE)	

O R D E R

On August 25, 2005, the Oldham County Water District ("Oldham District") applied for permission to deviate from Administrative Regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Oldham District states in its application that its average daily water usage, including unaccounted-for water, is approximately 4,176,249 gallons, and that its current water storage capacity is 7,595,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that Oldham District is in compliance with the requirements of Administrative Regulation 807 KAR 5:066, Section 4(4), and, as such, no deviation is required.


IT IS THEREFORE ORDERED that:

1. Oldham District is in compliance with the requirements of Administrative Regulation 807 KAR 5:066, Section 4(4).
2. Because no deviation is required, Oldham District's application is hereby dismissed without prejudice and is removed from the Commissioner's docket.

Done at Frankfort, Kentucky, this 15th day of March, 2006.

By the Commission

ATTEST:



Executive Director

Case No. 2005-00340