

A Touchstone Energy Cooperative 

March 24, 2009

RECEIVED

MAR 25 2009

PUBLIC SERVICE
COMMISSION

Director of Engineering
Public Service Commission
P.O. Box 615
Frankfort, KY 40602

RE: PSC Administrative Case No. 2006-00494

To Whom It May Concern:

Please find enclosed our 2008 Annual Reliability Report as required by the Kentucky PSC Administrative Case No. 2006-00494. We have included three (3) hard copies and one compact disk copy for your review.

If you have any questions or need further information, please feel free to contact me.

Sincerely,

OWEN ELECTRIC COOPERATIVE



James D. See, P.E.
Senior V.P. of Systems Planning
and Reliability

JDS/jlh

Enclosures

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 1: CONTACT INFORMATION

UTILITY NAME	1.1	Owen Electric Cooperative
REPORT PREPARED BY	1.2	James D. See
E-MAIL ADDRESS OF PREPARER	1.3	<u>jsee@owenelectric.com</u>
PHONE NUMBER OF PREPARER	1.4	<u>(502) 563 - 3498</u>

SECTION 2: REPORT YEAR

CALENDAR YEAR OF REPORT	2.1	<u>2008</u>
-------------------------	-----	-------------

SECTION 3: MAJOR EVENT DAYS

T_{MED}	3.1	<u>12.65</u>
FIRST DATE USED TO DETERMINE T_{MED}	3.2	<u>1/1/2003</u>
LAST DATE USED TO DETERMINE T_{MED}	3.3	<u>12/31/2007</u>
NUMBER OF MED IN REPORT YEAR	3.4	<u>8</u>

NOTE: Per IEEE 1366 T_{MED} should be calculated using the daily SAIDI values for the five prior years. If five years of data are not available, then utilities should use what is available until five years are accumulated.

SECTION 4: SYSTEM RELIABILITY RESULTS

Excluding MED

SAIDI	4.1	<u>111.57</u>
SAIFI	4.2	<u>1.34</u>
CAIDI	4.3	<u>84.84</u>

Including MED (Optional)

SAIDI	4.4	<u>851.84</u>
SAIFI	4.5	<u>2.98</u>
CAIDI	4.6	<u>285.67</u>

Notes:

- 1) All duration indices (SAIDI, CAIDI) are to be reported in units of minutes.
 - 2) Reports are due on the first business day of April of each year
 - 3) Reports cover the calendar year ending in the December before the reports are due.
 - 4) IEEE 1366 (latest version) is used to define SAIDI, SAIFI, CAIDI, and T_{MED}
-

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: OUTAGE CAUSE CATEGORIES

Excluding MED

CAUSE CODE DESCRIPTION	SAIDI VALUE	CAUSE CODE DESCRIPTION	SAIFI VALUE
Weather 5.1.1	24.71	Weather 5.2.1	0.31
Major Storm 5.1.2	21.58	Member/Public 5.2.2	0.18
ROW Preventable 5.1.3	17.27	Unknown 5.2.3	0.16
Unknown 5.1.4	11.35	ROW Preventable 5.2.4	0.16
Equipment/Installation 5.1.5	9.69	Major Storm 5.2.5	0.15
Member/Public 5.1.6	8.37	Equipment/Installation 5.2.6	0.11
Age/Deterioration 5.1.7	7.42	Power Supplier 5.2.7	0.08
Birds/Animals 5.1.8	2.98	Age/Deterioration 5.2.8	0.07
Power Supplier 5.1.9	2.83	Birds/Animals 5.2.9	0.05
Scheduled 5.1.10	2.73	Scheduled 5.2.10	0.04

SECTION 6: WORST PERFORMING CIRCUITS

CIRCUIT IDENTIFIER	SAIDI VALUE	MAJOR OUTAGE CATEGORY
1802	6.1.1 434.70	Weather
2001	6.1.2 363.36	R.O.W. Preventable
5202	6.1.3 350.00	Weather
5201	6.1.4 144.20	Power Supplier
5101	6.1.5 140.10	Major Storm
302	6.1.6 130.40	Equipment/Installation
1202	6.1.7 115.90	Major Storm
1503	6.1.8 114.80	Power Supplier
1505	6.1.9 111.50	Power Supplier
1706	6.1.10 106.10	Weather

CIRCUIT IDENTIFIER	SAIFI VALUE	MAJOR OUTAGE CATEGORY
2001	6.2.1 6.22	Equipment/Installation
1802	6.2.2 5.20	Unknown
5202	6.2.3 4.65	Power Supplier
5201	6.2.4 3.00	Power Supplier
1902	6.2.5 2.48	Birds/Animals
1503	6.2.6 2.40	Major Storm
2002	6.2.7 2.00	Power Supplier
5707	6.2.8 2.00	Power Supplier
2003	6.2.9 2.00	Power Supplier
1706	6.2.10 1.90	Birds/Animals

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

Additional pages may be attached as necessary

SECTION 7: VEGETATION MANAGEMENT PLAN REVIEW

In 2008, Owen Electric successfully completed 891 miles of right-of-way spraying and 817 miles of right-of-way trimming, in keeping with our 4-year cycle of maintenance. In 2008, we made more extensive use of our cross-country "sky-trim" to increase ROW trim clearance and enhance overall safety. We added a hydro axe late in 2008 and feel in 2009 it will greatly increase brush control in the ROW and allow for a more effective spray program the following year. Lastly, beginning January 2009, the addition of a mid-cycle trim program covering one-fourth of all circuits; the three phase line from the substation to the first set of breakers is checked for clearance and ground brush. The 2009 portion of this project has now been completed.

SECTION 8: UTILITY COMMENTS

In 2008 Owen Electric continued to enhance its effort to improve reliability. OEC worked more closely with customers, upgraded equipment, worked with our power supplier, did more inspections, and did more special ROW trimming. The result of that work has triggered three enhanced or new programs for 2009 at OEC. The first is the mid-cycle trim that is referred to and explained in the ROW write-up above, the second is a circuit hardening program where OEC evaluates the first section of a circuit from the substation to the first mainline protective device. Then based on the evaluation we would add/replace animal guards, replace gap arresters, remove CSP transformers, update protection coordination, and replace any marginal equipment. This program will start with the worst performing circuits. The third is an enhance maintenance program that will use a new specially trained crew to maintain on a regular bases all key distribution equipment.

As per Order 2006-00494 our ten worst performing circuits (WPC) based on SAIDI, SAIFI, and CAIDI (30 total), nine were caused by our power supplier, eight by major storm, seven by weather, two by equipment, two by bird/animals, one unknown, and one ROW. The nine due to power supplier were caused by two outages that affected two substations on one transmission line. We have and continue to work with our power supplier with addressing substation and transmission outages. The eight due to major storms were caused by the day before or after an MED day and were caused by major storms. The seven WPC due to weather were caused by severe weather that is beyond our design criteria. The two WPC caused by equipment were from two pieces of equipment that failed and required an additional scheduled outage to repair. OEC anticipates our enhanced maintenance program will eliminate some of these equipment failures. The two WPC caused by birds/animals were evaluated and found to have three locations that had multi animal caused outages. OEC had animal protection added to the equipment in those areas that didn't have it already. The one WPC caused by ROW was the result of one outage near the substation that took several hours to restore. This was a large yard tree that took out the line. We continue to work with our customers to get the maximum trimming we can regarding trees in the yard. The last WPC cause was unknown therefore, no action can be taken at this time.

Historical Reliability Index and charts have been included with this report as well.

Yearly System Indices Report

Year	SAIFI	SAIDI	CAIDI	# MEDs
2008	2.98	851.84	285.67	8
	1.34	111.57	83.22	
2007	2.31	207.74	89.84	2
	1.83	133.88	73.17	
2006	1.81	149.07	82.21	0
	1.81	149.07	82.21	
2005	1.74	143.09	82.4	
	1.74	143.09	82.4	
2004	2.03	292.4	144.09	3
	1.71	160.73	93.81	
2003	2.13	184.03	86.37	0
	2.13	184.03	86.37	
2002	2.25	214.06	95.13	1
	2.19	183.34	83.78	


* Major Event Day (MED) are based upon the IEEE Std 1366-2003 on Electric Power Distribution Reliability Indices.

□ = Unfiltered
 □ = MED filtered*


Notes:

- 1) 2002 was a partial year (April 10th - December 31st) therefore we applied a corrective multiplier of 1.25 to the SAIDI and SAIFI indices for comparison to the following years.
- 2) Deviations from our report last year are a result of corrections made to outage data that was identified during this years analysis.

Historical System Reliability Index Trends



Historical System Reliability Index Trends



—□— MED Filtered SAIDI

—— Linear (MED Filtered SAIDI)

Historical System Reliability Index Trends

