

CANNONSBURG WATER DISTRICT

1606 CANNONSBURG ROAD

ASHLAND, KY 41102

606-928-9808

FAX# 606-928-4788

www.cannonsburgwater.com

December 11, 2015

Mr. Jeff Derouen
Executive Director
Public Service Commission
PO Box 615
Frankfort, KY 40602

RECEIVED

DEC 16 2015

PUBLIC SERVICE
COMMISSION

RE: CASE NO 2014-00267
Surcharge Monthly Activity Report

Dear Mr. Derouen:

Please find this as our monthly Sur-Charge activity report.

1. Cannonsburg Water District is still not reading the Master Meters due to faulty equipment. Alan Morrison, PE of CI Thornburg Co met with the Siemens Mag Meter Co. in late November and set up a meeting for the Siemens Mag Meter Co. to come to our water district on December 8, 2015 to determine the reason for the meters not reading.
The Seimens Mag Meter Co. determined that the wire hook ups that connect to the registers were not water proof. They will have to change the registers and replace the wires with water proof wires. Once that has been done they should start reading. We have no time when they will be in. We have talked to several different companies and they all state that Seimens Mag Meter Co. is the best around. The trouble that we have had has been just a series of misfortunate errors.
2. CWD has found and repaired 10 water leaks throughout the District in the month of November 2015.
3. The Bids for the replacement of service lines are still not ready for bid due to the Master Meters not working at this time.

Sincerely,



Danny R. Clarkson
Manager
Enclosure