

Matthew G. Bevin
Governor

Charles G. Snaveley
Secretary
Energy and Environment Cabinet



Commonwealth of Kentucky
Public Service Commission

211 Sower Blvd.
P.O. Box 615
Frankfort Kentucky 40602-0615
Telephone: (502) 564-3940
Fax: (502) 564-3460
psc.ky.gov

April 12, 2017

Michael J. Schmitt
Chairman

Robert Cicero
Vice Chairman

Daniel E. Logsdon Jr.
Commissioner

PARTIES OF RECORD

RE: Case No. **2017-00142**

Whitley County Water District #1
(Deviation)
Minimum Pipe Size

The Commission Staff has reviewed the filing submitted April 10, 2017 and has determined that the application in the above case now meets the minimum filing requirements. Attached please find a stamped filed copy of the first page of your filing. This case has been docketed and will be processed as expeditiously as possible.

If you need further assistance, please contact my staff at 502-564-3940.

Sincerely,

A handwritten signature in black ink that reads "Talina R. Mathews".

Talina R. Mathews
Executive Director

TM/rs



Kenvirons, Inc.

452 Versailles Road • Frankfort, KY 40601 • Phone: (502) 695-4357 • Fax: (502) 695-4363

Civil & Environmental Engineering and Laboratory Services

March 21, 2017

Dr. Talina R. Mathews, Executive Director
Kentucky Public Service Commission
211 Sower Blvd.
P.O. Box 615
Frankfort, Kentucky 40602-0615

RECEIVED

MAR 21 2017

PUBLIC SERVICE
COMMISSION

RE: Blackhawk Road Water Line Extension
Whitley County Water District
Williamsburg, KY

Dear Dr. Mathews:

Case No. 2017-00142

Attached you will find the plans and hydraulic calculations for the above referenced proposed water line extension. As you will see the proposed line size is 2-inch for a distance of approximately 475 feet, which exceeds the Commission's limit of 200 feet. Therefore, we are requesting a variance per 807 KAR 51066 Water Section 10(2)(a) minimum pipe size.

1. Whitley County Water District is proposing to use the 2-inch distribution line instead of a larger line for the following reasons:
 - A. The District does not envision there ever being more than three (3) users on the line and the operating pressure is more than adequate to serve their peak demand.
 - B. There initially may only be one user on the line and the smaller line will provide fresher water.
 - C. The cost is being minimized as 2-inch line is slightly cheaper than 3-inch.

Plans and specifications are also being submitted this date to the Kentucky Division of Water for approval. Should you have any questions please call or e-mail me at KTaylor@Kenvirons.com.

Sincerely,

Kenneth D. Taylor, P.E.
Vice President

Attachments

C: WCWD

*Honorable Jane Butcher
Butcher, Bowling & Dixon Attorneys At Law
209 Main Street
P.O. Box 704
Williamsburg, KENTUCKY 40769

*Mr. Kenneth Taylor
Kenvirons, Inc.
452 Versailles Road
Frankfort, KENTUCKY 40602

*Whitley County Water District #1
19 S Highway 25W
Williamsburg, KY 40769