

DOC11R

**Case Management System - KY Public Service Commission***Regular Cases Before the Commission as of April 16, 2024***2017-00142**

RECEIVED: 03/21/17

FILED: 04/10/17

FINAL: 12/18/17

REOPENED:

SUSPENSION DATE:

CASE NATURE: Minimum Pipe Size

**CASE CODE**

Deviation

**UTILITIES:**

Whitley County Water District #1

**INDEX OF EVENTS:**

12/18/17	Final Order Entered: 1. WCWD's request for a deviation is granted. 2. WCWD shall be allowed to deviate from 807 KAR 5:066, Section 10(2)(a), to allow it to install approximately 475 feet of 2-inch pipe as part of the Blackhawk Road and Clyde Strunk Road Water Line Extensions.
09/18/17	Whitley County Water District No. 1 Information Response
09/11/17	Commission Staff's First Request for Information to Whitley County Water District No. 1
04/12/17	Deficiency Cured Letter
04/10/17	Whitley County Water District Response to Deficiencies
03/28/17	Deficiency letter, information due within 10 days
03/23/17	Acknowledge Receipt of Filing
03/21/17	Whitley County Water District #1 Request for Variance per 807 KAR 5:066, Section 10(2)(a) - Minimum Pipe Size

---

Total Number of Cases: 1