

DOC11R

**Case Management System - KY Public Service Commission***Regular Cases Before the Commission as of April 25, 2024***2017-00201**

RECEIVED: 05/12/17

FILED: 05/12/17

FINAL: 01/22/18

REOPENED:

SUSPENSION DATE:

CASE NATURE: Daily Inspection of Sewer Grinding Pump Stations

**CASE CODE**

Deviation

**UTILITIES:**

Garrison-Quincy-Ky-O-Heights Water District

**INDEX OF EVENTS:**

01/22/18	Final Order Entered: 1. GQWD's motion for extension of time is granted and its Answer to Commission Staff's First Request for Information is accepted for filing as of September 29, 2017. 2. GQWD's Application requesting an alternative inspection schedule for its grinder/pump stations pursuant to 807 KAR 5:071, Section 7(4) is approved. 3. Simplex grinder/pump stations shall be inspected annually.
09/29/17	Garrison-Quincy-KY-O-Heights Water District Motion for Extension of Time
09/07/17	Commission Staff's First Request for Information to Garrison-Quincy-KY-O-Heights Water District
05/15/17	Acknowledge Receipt of Filing
05/12/17	Garrison-Quincy-KY-O-Heights Water District Request for Deviation from Daily Inspection of Sewer Grinding Pump Stations

---

Total Number of Cases: 1