

COMMONWEALTH OF KENTUCKY  
BEFORE THE ENERGY REGULATORY COMMISSION

\* \* \* \* \*

In the Matter of

APPLICATION OF DELORES BURKE, )  
VAN LEAR, KENTUCKY, TO DEVIATE )  
FROM COMMISSION REGULATION ) CASE NO. 7807  
807 KAR 50:045 SECTION 6, SUBPART 6 )

O R D E R

On February 25, 1980, Delores Burke, Van Lear, Kentucky, filed a letter with the Commission requesting authority to use 1-1/4 inch plastic pipe in the construction of a service line from his house to a gas line of Kentucky West Virginia Gas Company.

The Commission decided to treat this letter as an Application requesting authority to deviate from the provisions of Commission Regulation 807 KAR 50:045 Section 6, Subpart 6.

A member of the Commission staff inspected the proposed location of the service line and found that it would be possible to bury the line to a sufficient depth to prevent damage to same by various surface plowing and digging activities and recommended the granting of the requested authority.

The Commission, having considered the Application, all evidence of record and being fully advised, is of the opinion and finds:

1. That a hearing to consider the merits of the application will not be necessary.
2. That Ms. Burke should be granted permission to use 1-1/4 inch plastic pipe in lieu of black steel pipe provided the pipe is of an approved type and is buried a minimum of 36 inches.
3. That the completed service line installation shall be inspected by Commission staff members prior to the filling of the ditch.
4. That Ms. Burke shall notify the Commission when construction is sufficiently completed to allow for the above inspection.


5. That Ms. Burke shall meet all other requirements of the Energy Regulatory Commission Regulation 807 KAR 50:045 Section 6 in her installations.

IT IS THEREFORE ORDERED that Delores Burke, Van Lear, Kentucky, be and she hereby is granted authority to deviate from the Energy Regulatory Commission Regulation 807 KAR 50:045 Section 6, Subpart 6 and install one and one-fourth (1-1/4) inch plastic pipe of an approved type in his service line said pipe to be buried a minimum of 36 inches.


IT IS FURTHER ORDERED that Ms. Burke notify the Commission when construction is sufficiently completed to allow for the inspection and approval of the line by the Energy Regulatory Commission's Division of Utility Engineering and Services before service is rendered.

Done at Frankfort, Kentucky, this 23rd day of April, 1980.

ENERGY REGULATORY COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

\_\_\_\_\_  
Secretary