

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

* * * * *

In the Matter of

WHEELER SLONE, FISHTRAP, KENTUCKY,)
TO DEVIATE FROM COMMISSION)
REGULATION 807 KAR 5:026, SECTION) CASE NO. 8522
6, SUBSECTION 6)

O R D E R

The Commission, having been notified that, due to the presence of rock, it will not be possible to safely install a plastic gas service line and that Mr. Slone will utilize steel pipe in accordance with the requirements of 807 KAR 5:026, Section 6, Subsection 6, HEREBY ORDERS that the above case be, and it hereby is, dismissed.

Done at Frankfort, Kentucky, this 28th day of July, 1982.

PUBLIC SERVICE COMMISSION

Marlin M. Vohy
Chairman

Katherine Randall
Vice Chairman

Donna M. Gage
Commissioner

ATTEST:

Secretary