

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

* * * * *

In the Matter of:

THE APPLICATION OF EDWARD NAIRN)	
OF ELLIOTT CONTRACTING, BOX 2705,)	
PIKEVILLE, KENTUCKY, ON BEHALF)	
OF BERTHA STURGILL, ROUTE 1,)	CASE NO. 8581
BOX 1060, HAROLD, KENTUCKY, TO)	
DEVIATE FROM COMMISSION REGULA-)	
TION 807 KAR 5:026, SECTION 6,)	
SUBSECTION 6)	

O R D E R

On August 3, 1982, Edward Nairn of Elliott Contracting filed a letter with the Commission on behalf of Bertha Sturgill, Route 1, Box 1060, Harold, Kentucky, requesting authority to use 1-1/4-inch plastic pipe in the construction of a service line to Mrs. Sturgill's residence from a line of the Cities Service Oil Company.

The Commission will treat this letter as an application requesting authority to deviate from the provisions of Commission Regulation 807 KAR 5:026, Section 6, Subsection 6.

A member of the Commission staff inspected the proposed location of the service line and found that it would be possible to bury the line to a sufficient depth to prevent damage to same by various digging activities and recommended the granting of the requested authority.

The Commission, having considered the application and all evidence of record and being fully advised, is of the opinion and finds that:

1. A hearing to consider the merits of the application will not be necessary.

2. Mr. Nairn should be granted permission to use 1.1/4 inch plastic pipe in lieu of black steel pipe for Mrs. Sturgill's service line provided the pipe is of an approved type and the entire service line is buried a minimum of 36 inches.

3. The completed service line installation should be inspected by Commission staff members prior to the filling of the ditch.

4. Mr. Nairn or Mrs. Sturgill should notify the Commission when construction is sufficiently completed to allow for the above inspection.

5. The plastic pipe should be installed by persons who qualify under the requirements of 49 CFR 192.285.

6. This service line should be used only to serve one dwelling as required by 807 KAR 5:026, Section 6, Subsection 2.

7. Mr. Nairn should meet all other requirements of Public Service Commission Regulation 807 KAR 5:026, Section 6, in the installations.

IT IS THEREFORE ORDERED that Mr. Nairn on behalf of Mrs. Sturgill be and he hereby is granted authority to deviate from Public Service Commission Regulation 807 KAR 5:026, Section 6,

Subsection 6, and install 1 1/4 inch plastic pipe of an approved type for this service line, said pipe to be buried a minimum of 36 inches.

IT IS FURTHER ORDERED that Mr. Nairn or Mrs. Sturgill shall notify the Commission when construction is sufficiently completed to allow for the inspection and approval of the line by the Division of Utility Engineering and Services of the Public Service Commission before service is rendered.

Done at Frankfort, Kentucky, this 13th day of August, 1982.

PUBLIC SERVICE COMMISSION

Marlin M. York
Chairman

Katharine Bendall
Vice Chairman

Jim Carrigan
Commissioner

ATTEST:

Secretary