

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF THE LEVEE ROAD)
WATER ASSOCIATION, INC., A NON-)
STOCK, CORPORATION ORGANIZED)
PURSUANT TO CHAPTER 273 OF THE)
KENTUCKY REVISED STATUTES, OF)
MONTGOMERY COUNTY, KENTUCKY, FOR)
(1) A CERTIFICATE OF PUBLIC)
CONVENIENCE AND NECESSITY,)
AUTHORIZING AND PERMITTING SAID) CASE NO. 9212
ASSOCIATION TO EXPAND ITS DISTRI-)
BUTION SYSTEM TO ADDITIONAL)
TERRITORY NOT SERVED BY ANY WATER)
SOURCE: (2) APPROVAL OF THE)
PROPOSED PLAN OF FINANCING OF)
SAID PROJECT: AND (3) APPROVAL)
OF THE WATER RATES PROPOSED TO)
BE CHARGED BY THE ASSOCIATION TO)
CUSTOMERS OF THE ASSOCIATION)

O R D E R

IT IS ORDERED that Levee Road Water Association ("Levee Road") shall file an original and 7 copies of the following information with the Commission with a copy to all parties of record by May 24, 1985. Levee Road shall also furnish with each response the name of the witness who will be available at the public hearing for responding to questions concerning each area of information requested. If neither the requested information nor a motion for an extension of time is filed by the stated date, the case may be dismissed.

1. Levee Road filed computer hydraulic analyses and a hydraulic gradient sheet for the proposed water distribution system in response to the Commission's April 2, 1985, Information Request. This information indicates that the potential exists for the water line on Kiddville Road to experience low pressure (less than 30 psig) and at times even "negative pressure" near the mid-point of the existing portion of this water line. Provide details of any preventive measures and/or additional construction that Levee Road intends to perform to protect against this type of occurrence. Details should be documented by hydraulic analyses and field measurements.

Done at Frankfort, Kentucky, this 10th day of May, 1985.

PUBLIC SERVICE COMMISSION


For the Commission

ATTEST:

Secretary