

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF SOUTHEAST DAVIESS )  
COUNTY WATER DISTRICT FOR APPROVAL )  
OF DEVIATION FROM SECTION 5 (4); 807 ) CASE NO. 9887  
KAR 5:066 )

O R D E R

On March 13, 1987, Southeast Daviess County Water District ("Southeast Daviess") filed an application with the Public Service Commission for approval of deviation from 807 KAR 5:066, Section 5 (4), which requires each water utility to provide water storage to insure a minimum of one day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. Southeast Daviess maintains 750,000 gallons as above ground storage and the average daily consumption for 1986 was 1,075,692 gallons.
2. Southeast Daviess' source of water supply has never been out of service in the 22-year history of its operation.
3. Except for the county school system, Southeast Daviess states that there are no emergency or critical facilities served by the utility.


IT IS THEREFORE ORDERED that:


1. Deviation from 807 KAR 5:066, Section 5 (4), be and it hereby is granted until July 1, 1990.

2. Southeast Daviess shall review its water storage situation prior to the expiration date of this deviation and either construct the required amount of storage or apply for continued deviation from the regulation.

Done at Frankfort, Kentucky, this 26th day of June, 1987.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

\_\_\_\_\_  
Executive Director