

COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF KIRKSVILLE WATER)
ASSOCIATION, INC., FOR A DEVIATION) CASE NO. 10179
FROM THE WATER STORAGE REQUIREMENTS)

O R D E R

By letter received March 2, 1988, Kirksville Water Association, Inc., ("Kirksville Water") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a water utility to insure one day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. Kirksville Water has one water storage tank with a total capacity of 100,000 gallons.
2. Kirksville Water's average daily water usage for the 12-month period ending December 31, 1987, was 133,333 gallons.
3. Kirksville Water does not have storage capacity to insure one day's supply of its average water usage and, therefore, does not meet the requirements of Commission regulation 807 KAR 5:066, Section 5(4).
4. Kirksville Water has not experienced a significant interruption in service in more than 4 years.

5. Kirksville Water should be granted a deviation from 807 KAR 5:066, Section 5(4) until July 1, 1991, to proceed with the construction of additional water storage to meet Commission regulations.

6. Kirksville Water should take all necessary steps to increase its water storage capacity to equal or exceed its average daily usage.


IT IS THEREFORE ORDERED that:

1. Kirksville Water be and it hereby is granted a deviation from 807 KAR 5:066, Section 5(4) until July 1, 1991.

2. Kirksville Water shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to the expiration of the deviation herein granted.

Done at Frankfort, Kentucky, this 22nd day of April, 1988.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director