

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF GARRISON, QUINCY,)
KY-O-HEIGHTS WATER DISTRICT FOR A)
DEVIATION FROM THE REQUIREMENTS OF) CASE NO. 10299
807 KAR 5:066, SECTION 5(4) REGARDING)
WATER STORAGE)

O R D E R

By letter received June 15, 1988, Garrison, Quincy, KY-O-Heights Water District ("Garrison") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a water utility to insure one day's supply of its average daily usage.

On September 9, 1988, Garrison partially responded to the Commission's Information Request Order dated July 11, 1988. Garrison failed to respond to the following questions:

1. Provide a technical summary of operational deficiencies of Garrison's water system that are known from experience or that have been indicated by hydraulic analyses.
2. List names and addresses of Garrison's customers that are providing critical health services.
3. Show number of hours under present operating conditions that service can be continued to hospitals, schools, and other similar facilities after an interruption of service by Garrison's supplier when the supply requirements to be met are: (a) maximum 24-hour volume, (b) average 24-hour volume, and (c) minimum

24-hour volume. Provide supplemental information as needed to explain how results for (a), (b), and (c) were obtained.

4. If the Farmers Homes Administration ("FmHA") holds any of Garrison's long-term debt, provide a copy of an FmHA letter stating its position with regard to the storage volume provided by Garrison and its request for a deviation from Commission regulations.

Garrison's response to question 2 of the Commission's Order of July 11, 1988 was not adequate since it did not present an adequate map showing the location of the treatment plant, main lines, and the storage tanks.

IT IS THEREFORE ORDERED that Garrison shall file an original and 7 copies of the following information with the Commission, with a copy to all parties of record, no later than October 5, 1988.

1. Garrison shall respond to questions 1, 2, 3, and 4 mentioned above.

2. Garrison shall file an adequate map of its system showing the location of the producing wells, treatment plant, main lines, and storage tanks.

If this information cannot be provided by October 5, 1988, Garrison should submit a motion for an extension of time stating the reason a delay is necessary and include a date by which it will be furnished. Such motion will be considered by the Commission. Garrison shall furnish with each response the name of

the witness who will be available for responding to questions concerning each item of information requested should a public hearing be required in this matter.

Done at Frankfort, Kentucky, this 20th day of September, 1988.

PUBLIC SERVICE COMMISSION

Richard D. Henshaw

For the Commission

ATTEST:

Executive Director