## COMMONWEALTH OF KENTUCKY

## BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF GARRISON, QUINCY,	)		
KY-O-HEIGHTS WATER DISTRICT FOR A	)		
DEVIATION FROM THE REQUIREMENTS OF	)	CASE NO.	10299
807 KAR 5:066, SECTION 5(4) REGARDING	)		
WATER STORAGE	)		

## ORDER

By letter received June 15, 1988, Garrison, Quincy, KY-O-Heights Water District ("Garrison") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a water utility to provide water storage to insure one day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

- 1. Garrison is not currently in compliance with Commission Regulation 807 KAR 5:066, Section 5(4) because it does not provide an adequate capacity of water storage to its system.
- 2. Garrison sold a daily average of 144,000 gallons of water in 1987.
- 3. Garrison provides a 105,000-gallon storage tank which is less than its daily average consumption rate.
- 4. Garrison does not supply customers who provide critical health care services.

IT IS THEREFORE ORDERED that Garrison be and hereby is granted a deviation from 807 KAR 5:066, Section 5(4) until July 1, 1991 to pursue its effort to provide additional storage capacity in order to comply with the Commission regulation.

Done at Frankfort, Kentucky, this 20th day of October, 1988.

PUBLIC SERVICE COMMISSION

Chairman

Vice Chairman

Sur Williams

ATTEST:

Executive Director