

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF JONATHAN CREEK)
WATER ASSOCIATION, INC., FOR A)
DEVIATION FROM THE REQUIREMENTS OF) CASE NO. 10302
807 KAR 5:066, SECTION 5(4) REGARDING)
WATER STORAGE)

O R D E R

By letter received June 29, 1988, Jonathan Creek Water Association, Inc. ("Jonathan") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a water utility to provide water storage to insure one day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. Jonathan is not currently in compliance with Commission Regulation 807 KAR 5:066, Section 5(4) because it does not provide adequate water storage to its system.
2. Jonathan provided a daily average of 405,000 gallons of water in 1987.
3. Jonathan provides a 350,000-gallon storage capacity to its water system.
4. Jonathan supplies water to two large consumers, Kenlake State Park ("Kenlake") and Lakeland Wesley Village ("Lakeland"). Kenlake consumed a maximum of 13.9 percent of Jonathan's water in 1987. Lakeland consumed 4.5 percent of Jonathan's water in 1987.

Kenlake provides a 100,000-gallon elevated storage tank for its use. Lakeland has no storage facility.

5. None of Jonathan's customers provide critical health care services.

6. Jonathan should provide an adequate water tank to comply with the regulation 807 KAR 5:066, Section 5(4).


IT IS THEREFORE ORDERED that:

1. Jonathan be and it hereby is granted a deviation from 807 KAR 5:066, Section 5(4) until July 1, 1991.

2. Jonathan shall provide adequate storage to comply with Commission regulation 807 KAR 5:066, Section 5(4) no later than July 1, 1991.

Done at Frankfort, Kentucky, this 3rd day of October, 1988.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director