

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF HIMA-SIBERT)
WATER DISTRICT FOR A DEVIATION)
FROM 807 KAR 5:066, SECTION) CASE NO. 10484
5(4), REGARDING WATER STORAGE)

O R D E R

By letter received November 21, 1988, Hima-Sibert Water District, ("Hima-Sibert") requested a deviation from 807 KAR 5:066, Section 5(4). This regulation requires a water utility to provide water storage to insure one day's supply of its average daily water usage.

Additional information is needed for an adequate and proper consideration of the deviation requested by Hima-Sibert.

IT IS THEREFORE ORDERED that Hima-Sibert shall file an original and 7 copies of the following information with the Commission, with a copy to all parties of record, no later than January 16, 1989.

1. Provide the current average daily usage on Hima-Sibert's system.
2. Provide the number and capacity of any water storage tanks on Hima-Sibert's system.
3. Provide details with documentation of the rationale under which Hima-Sibert requests this deviation (e.g. supplier

provides storage capacity, time is needed to study and implement a plan to add storage capacity, etc.).

If this information cannot be provided by January 16, 1989, Hima-Sibert should submit a motion for an extension of time stating the reason a delay is necessary and include a date by which it will be furnished. Such motion will be considered by the Commission. Hima-Sibert shall furnish with each response the name of the witness who will be available for responding to questions concerning each item of information requested should a public hearing be required in this matter.

Done at Frankfort, Kentucky, this 20th day of December, 1988.

PUBLIC SERVICE COMMISSION



For the Commission

ATTEST:

Executive Director