

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF DAVID WATER)
DISTRICT FOR A DEVIATION FROM)
807 KAR 5:066, SECTION 5(4),) CASE NO. 10482
REGARDING WATER STORAGE)

O R D E R

By letter received November 17, 1988, David Water District, ("David Water") requested a deviation from 807 KAR 5:066, Section 5(4). This regulation requires a water utility to provide water storage to insure 1 day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. David Water's current average daily usage is 25,130 gallons.

2. David Water has no storage facilities on its water system.

3. David Water has stated that it does not need its own storage facilities as storage capacity is provided by its supplier, the Beaver Elkhorn Water District ("Beaver Elkhorn").

4. David Water should file with the Commission a written agreement between Beaver Elkhorn and David Water that states a firm commitment from Beaver Elkhorn to provide the daily demand of David Water during an emergency and that David Water shall be treated as any customer of Beaver Elkhorn during emergency


conditions. Such an agreement should be filed with the Commission no later than February 28, 1989.

IT IS THEREFORE ORDERED that David Water shall be and hereby is granted a deviation from the water storage requirements of 807 KAR 5:066, Section 5(4) contingent upon its filing with the Commission a firm agreement with Beaver Elkhorn as outlined in Finding 4 on or before February 28, 1989. In the event no such agreement is filed, David Water shall comply with the provisions of 807 KAR 5:066, Section 5(4).

Done at Frankfort, Kentucky, this 1st day of February, 1989.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director