

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WACO WATER)
DISTRICT FOR A DEVIATION FROM 807)
KAR 5:066, SECTION 5(4) REGARDING)
WATER STORAGE) CASE NO. 10493

O R D E R

By letter received December 15, 1988, Waco Water District ("Waco Water") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a utility to provide water storage to insure a minimum of one day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. Waco Water filed a letter written by Richmond Utilities and addressed to Waco Water, which states that the capacity of Richmond Utilities to provide adequate water supply to Waco Water is excellent. Richmond Utilities provides a 5,000,000-gallon water storage tank located in close proximity to Waco Water's master meter.


2. Waco Water should file with the Commission a written agreement between Richmond Utilities and Waco Water that states a firm commitment from Richmond Utilities to provide the daily demand of Waco Water during emergency and that Waco Water shall be

treated as any customer of Richmond Utilities during emergency conditions. Such an agreement should be filed with the Commission no later than March 30, 1989.

IT IS THEREFORE ORDERED that Waco Water shall be and hereby is granted a deviation from the water storage requirement of 807 KAR 5:066, Section 5(4) contingent upon its filing with the Commission a firm agreement with Richmond Utilities as outlined in Finding 2 on or before March 30, 1989. In the event no such agreement is filed, Waco Water shall comply with the provisions of 807 KAR 5:066, Section 5(4).

Done at Frankfort, Kentucky, this 5th day of January, 1989.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director