

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF ALLEN COUNTY WATER)
DISTRICT FOR A DEVIATION FROM THE)
REQUIREMENTS OF 807 KAR 5:066, SECTION) CASE NO. 89-162
5(4) REGARDING WATER STORAGE)

O R D E R

By application received June 15, 1989, Allen County Water District ("Allen County") requested a deviation from 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to insure a minimum of 1 day's supply of its average daily water usage.


The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:


1. Allen County's average daily water usage including unaccounted-for water is 81,715 gallons.
2. Allen County's current water storage capacity is 164,000 gallons.
3. Since Allen County has available an amount of water storage sufficient to meet the requirements of 807 KAR 5:066, Section 5(4), no deviation is required.

IT IS THEREFORE ORDERED that this case be and it hereby is dismissed.

Done at Frankfort, Kentucky, this 14th day of July, 1989.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director