

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WARREN COUNTY )  
WATER DISTRICT FOR A DEVIATION )  
FROM THE REQUIREMENTS OF 807 KAR ) CASE NO. 89-172  
5:066, SECTION 5(4), REGARDING )  
WATER STORAGE )

O R D E R

By application received June 26, 1989, Warren County Water District ("Warren County") requested a deviation from 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of 1 day's supply of its average daily water usage. Warren County states in its application that its average daily water usage including unaccounted-for water is 3,915,000 gallons, and its current water storage capacity is 2,629,000 gallons.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. Warren County's current water storage facilities are not deemed adequate and are therefore not in compliance with 807 KAR 5:055, Section 5(4).

2. Warren County is currently in the construction and planning stages on improvement projects for its water distribution system. Additional water storage facilities are included in its improvement program.

3. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Warren County should be given until August 5, 1992 to bring it within compliance of the Commission's water storage requirements.


IT IS THEREFORE ORDERED that:


1. Warren County be and it hereby is given until August 5, 1992 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. Warren County shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to August 5, 1992.

Done at Frankfort, Kentucky, this 2nd day of August, 1989.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

\_\_\_\_\_  
Executive Director