

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF PULASKI COUNTY WATER)
DISTRICT NO. 2 FOR A DEVIATION FROM THE)
REQUIREMENTS OF 807 KAR 5:066, SECTION) CASE NO. 89-191
5(4) REGARDING WATER STORAGE)

O R D E R

By application received June 11, 1989, Pulaski County Water District No. 2 ("Pulaski No. 2") requested a deviation from 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of 1 day's supply of its average daily water usage. Pulaski No. 2 states in its application that its average daily water usage including unaccounted-for water is 281,603 gallons, and its current water storage capacity is 317,000 gallons.


The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that Pulaski No. 2 has available an amount of water storage sufficient to meet the requirements of 807 KAR 5:066, Section 5(4), and no deviation is required.

IT IS THEREFORE ORDERED that the application of Pulaski No. 2 for permission to deviate from the requirements of 807 KAR 5:066, Section 5(4), is denied.

Done at Frankfort, Kentucky, this 28th day of July, 1989.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director