COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF HARDEMAN WATER) DISTRICT FOR A DEVIATION FROM THE) REQUIREMENTS OF 807 KAR 5:066, SECTION) CASE NO. 90-014 5(4), REGARDING WATER STORAGE)

ORDER

By application received January 17, 1990, Hardeman Water District ("Hardeman") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Hardeman states in its application that its average daily water usage, including unaccounted-for water, is approximately 88,000 gallons, and its current water storage capacity is 50,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Hardeman is not in compliance with the requirements of Commission Regulation 807 KAR 5:066, Section 5(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Hardeman should be given until March 1, 1993 to bring it within compliance of the Commission's water storage requirements. IT IS THEREFORE ORDERED that:

1. Hardeman be and it hereby is given until March 1, 1993 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. Hardeman shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to the expiration date of the deviation herein granted.

Done at Frankfort, Kentucky, this 12th day of February, 1990.

PUBLIC SERVICE COMMISSION

Commissioner

ATTEST: