

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF NICHOLAS COUNTY )  
WATER DISTRICT FOR A DEVIATION FROM )  
THE MINIMUM WATER STORAGE REQUIREMENT ) CASE NO. 90-148  
OF 807 KAR 5:066, SECTION 5(4) )

O R D E R

By application received May 22, 1990, Nicholas County Water District ("Nicholas Water") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Nicholas Water states in its application that its average daily water usage, including unaccounted-for water, is approximately 70,187 gallons, and that its current water storage capacity is 50,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Nicholas Water is not in compliance with Commission Regulation 807 KAR 5:066, Section 5(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Nicholas Water should be given until July 1, 1993 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 5(4).


IT IS THEREFORE ORDERED that:

1. Nicholas Water be and it hereby is given until July 1, 1993 to comply with the provisions of 807 KAR 5:066, Section 5(4).


2. Nicholas Water shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to July 1, 1993.

Done at Frankfort, Kentucky, this 21st day of June, 1990.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

  
Executive Director