

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF SOUTH SHORE WATER WORKS)	
FOR A DEVIATION FROM THE REQUIREMENTS OF)	CASE NO.
807 KAR 5:066, SECTION 5(4), REGARDING)	90-194
WATER STORAGE)	

O R D E R

On July 6, 1990, the South Shore Water Works Company ("South Shore") filed an application for a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall maintain water storage to ensure a minimum of one day's supply of its average daily water usage. South Shore described its application as a request that the Commission reconsider its determination of minimum storage capacity reached in Case No. 10263.¹ In its application, South Shore computed its average daily water usage to be 364,890 gallons. It claims to have a current water storage capacity of 432,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. In its Order of July 20, 1988, in Case No. 10263, the Commission granted South Shore a limited deviation from 807 KAR

¹ Case No. 10263, The Application of South Shore Water Works Company for a Deviation from the Requirements of 807 KAR 5:066, Section 5(4), Regarding Water Storage.

5:066, Section 5(4), until August 1, 1991. South Shore subsequently provided evidence which adjusted its average daily water usage and, by Order of November 9, 1988, the Commission accepted South Shore's adjustments on the condition that South Shore obtain a written agreement with Didier Taylor, a large industrial customer, that water service would be terminated to Didier Taylor during emergency conditions. South Shore was directed to file the agreement with the Commission no later than December 1, 1988.

2. South Shore to this date has not provided the above-described agreement. Inasmuch as South Shore has failed to file this agreement, the Commission's Order of July 20, 1988, issued in Case No. 10263, remains in effect.

IT IS THEREFORE ORDERED that South Shore's application of July 6, 1990 is hereby denied and South Shore remains bound by the Commission's Order of July 20, 1988 in Case No. 10263 to bring its water storage facilities in compliance with 807 KAR 5:066, Section 5(4), by August 1, 1991.

Done at Frankfort, Kentucky, this 17th day of August, 1990.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman

ATTEST:


Executive Director


Commissioner