

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF BLACK MOUNTAIN)
UTILITY DISTRICT FOR A DEVIATION FROM)
THE REQUIREMENTS OF 807 KAR 5:066,)
SECTION 5(4) REGARDING WATER STORAGE) CASE NO. 91-003

O R D E R

By application received January 3, 1991, Black Mountain Utility District ("Black Mountain") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Black Mountain states in its application that its average daily water usage, including unaccounted-for water, is approximately 22,000 gallons, and that it does not have any water storage facilities.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Black Mountain is not in compliance with Commission Regulation 807 KAR 5:066, Section 5(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Black Mountain should be given until July 1, 1994 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 5(4).


IT IS THEREFORE ORDERED that:

1. Black Mountain be and it hereby is given until July 1, 1994 to comply with the provisions of 807 KAR 5:066, Section 5(4).


2. Black Mountain shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to July 1, 1994.

Done at Frankfort, Kentucky, this 15th day of February, 1991.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director