

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF FANCY FARM WATER)
DISTRICT FOR A DEVIATION FROM 807 KAR)
5:066, SECTION 5(4) REGARDING WATER)
STORAGE)
CASE NO. 91-261

O R D E R

By application received July 30, 1991, Fancy Farm Water District ("Fancy Farm") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Fancy Farm states in its application that its average daily water usage, including unaccounted-for water, is approximately 130,000 gallons, and that its current water storage capacity is 100,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Fancy Farm is not in compliance with Commission Regulation 807 KAR 5:066, Section 5(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Fancy Farm should be given until January 1, 1995 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 5(4).


IT IS THEREFORE ORDERED that:

1. Fancy Farm be and it hereby is given until January 1, 1995 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. Fancy Farm shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 1995.

Done at Frankfort, Kentucky, this 9th day of September, 1991.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman

Commissioner

ATTEST:


Executive Director