

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WESTERN MASON WATER)
DISTRICT FOR A DEVIATION FROM THE)
REQUIREMENTS OF 807 KAR 5:066, SECTION) CASE NO. 91-263
6(2) AND (3) REGARDING ANNUAL PRESSURE)
SURVEYS)

O R D E R

By letter received July 26, 1991, Western Mason Water District ("Western Mason") requested a deviation from 807 KAR 5:066, Section 6(2) and (3), which requires a utility to own a recording pressure gauge, and to perform and maintain records of annual pressure surveys.

The Commission, having reviewed the evidence of record and being otherwise sufficiently advised, finds that:

1. Western Mason does not own a recording pressure gauge and is not performing or maintaining records of annual pressure surveys and is therefore not in compliance with 807 KAR 5:066, Section 6(2) and (3).

2. Western Mason has failed to show that good cause exists to grant it a deviation from 807 KAR 5:066, Section 6(2) and (3).

IT IS THEREFORE ORDERED that:


1. Western Mason's request for a deviation from 807 KAR 5:066, Section 6(2) and (3) is hereby denied.


2. Within 6 months of the date of this Order Western Mason shall obtain an operating recording pressure gauge and shall

perform and maintain records of annual pressure surveys in accordance with 807 KAR 5:066, Section 6(2) and (3).

Done at Frankfort, Kentucky, this 20th day of September, 1991.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman

Commissioner

ATTEST:


Executive Director