

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF OVERLAND DEVELOPMENT, )  
INC. FOR A DEVIATION PURSUANT TO 807 KAR )  
5:066, SECTION 5(4), REGARDING WATER )  
STORAGE )

CASE NO. 91-388

O R D E R

On October 25, 1991, Overland Development, Inc. ("Overland") filed an application for a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which requires that each utility shall maintain water storage to ensure a minimum of one day's supply of its average daily water usage.

On December 4, 1991, Overland filed a letter from its supplier, Big Sandy Water District ("Big Sandy"), in which Big Sandy assured Overland of adequate storage capacity. Big Sandy has a 300,000-gallon storage tank within 3,000 feet of Overland's master meter.


The Commission, having reviewed the application and information submitted subsequent thereto, and being otherwise sufficiently advised, finds that:

1. Overland has no water storage tanks in operation in its water distribution system.
2. Overland's average daily water usage is approximately 18,300 gallons per day.
3. Big Sandy is willing to provide Overland with needed storage capacity.


IT IS THEREFORE ORDERED that Overland be and it hereby is granted a deviation from the water storage requirements of 807 KAR 5:066, Section 5(4), for so long as its agreement with Big Sandy remains in effect, but no later than January 1, 1997.

Done at Frankfort, Kentucky, this 7th day of January, 1992.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

  
Executive Director