

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF EAST CLARK WATER)
DISTRICT FOR A DEVIATION FROM 807 KAR)
5:066, SECTION 5(4) REGARDING WATER) CASE NO. 91-453
STORAGE)

O R D E R

By application received December 6, 1991, East Clark Water District ("East Clark") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. East Clark states in its application that its average daily water usage, including unaccounted-for water, is approximately 211,200 gallons, and that its current water storage capacity is 200,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. East Clark is not in compliance with Commission Regulation 807 KAR 5:066, Section 5(4).
2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, East Clark should be given until January 1, 1995 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 5(4).

IT IS THEREFORE ORDERED that:


1. East Clark be and it hereby is given until January 1, 1995 to comply with the provisions of 807 KAR 5:066, Section 5(4).


2. East Clark shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 1995.

Done at Frankfort, Kentucky, this 16th day of January, 1992.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director