

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF JONATHAN CREEK WATER)
ASSOCIATION, INC. FOR A DEVIATION FROM)
THE REQUIREMENTS OF 807 KAR 5:066,) CASE NO. 91-469
SECTION 5(4), REGARDING WATER STORAGE)

O R D E R

By application received December 23, 1991, Jonathan Creek Water Association, Inc. ("Jonathan Creek") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Jonathan Creek states in its application that it is in the process of obtaining the necessary financing to construct additional water storage facilities.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Jonathan Creek is not in compliance with Commission Regulation 807 KAR 5:066, Section 5(4).
2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Jonathan Creek should be given until July 1, 1997 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 5(4).


IT IS THEREFORE ORDERED that:


1. Jonathan Creek be and it hereby is given until July 1, 1997 to comply with the provisions of 807 KAR 5:066, Section 5(4).


2. Jonathan Creek shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to July 1, 1997.

Done at Frankfort, Kentucky, this 27th day of January, 1992.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director