

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF STRINGTOWN WATER)	
DISTRICT FOR A DEVIATION PURSUANT TO 807)	CASE NO.
KAR 5:066, SECTION 5(4), REGARDING WATER)	92-068
STORAGE)	

O R D E R

On February 18, 1992, Stringtown Water District ("Stringtown") filed an application for a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which requires that each utility shall maintain adequate water storage to ensure a minimum of one day's supply of its average daily water usage.

On October 5, 1992, Stringtown filed a copy of the water supply agreement between the city of Lawrenceburg and Stringtown. On November 9, 1992, Stringtown filed with the Commission a letter from the city of Lawrenceburg which indicated and assured that Lawrenceburg would provide Stringtown's needed storage through the period of the existing supply contract, which runs until May 31, 2011.

The Commission, having reviewed the application and information submitted subsequent thereto, and being otherwise sufficiently advised, finds that:


1. Stringtown has no water storage tanks in its distribution system.
2. Stringtown's average daily water usage is approximately 32,000 gallons per day.


3. The city of Lawrenceburg is willing to provide Stringtown with needed storage capacity for the period through May 31, 2011.

IT IS THEREFORE ORDERED that Stringtown be and it hereby is granted a deviation from the water storage requirements of 807 KAR 5:066, Section 5(4), for so long as its agreement with the city of Lawrenceburg remains in effect.

Done at Frankfort, Kentucky, this 4th day of December, 1992.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director