

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF KINGSTON-TERRILL	)	
WATER DISTRICT FOR A DEVIATION FROM	)	CASE NO.
WATER STORAGE REGULATION 807 KAR 5:066,	)	93-237
SECTION 4(4)	)	

O R D E R

By application received July 8, 1993, Kingston-Terrill Water District ("Kingston-Terrill") requested a deviation from Commission Regulation 807 KAR 5:066, Section 4(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Kingston-Terrill states in its application that it is in the process of obtaining the necessary financing to construct additional water storage facilities. Kingston-Terrill also filed a letter from Richmond Water, Gas & Sewerage Works which indicated that a new water storage tank in the Richmond Industrial Park could be considered as supplemental storage for Kingston-Terrill's system.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Kingston-Terrill is not in compliance with Commission Regulation 807 KAR 5:066, Section 4(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Kingston-Terrill should be given until July 1, 1998 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:


1. Kingston-Terrill be and it hereby is given until July 1, 1998 to comply with the provisions of 807 KAR 5:066, Section 4(4).

2. Kingston-Terrill shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to July 1, 1998.


3. Kingston-Terrill shall ensure that it has adequate supplemental water storage available to it until its water storage facilities are brought into compliance with Commission regulations.

Done at Frankfort, Kentucky, this 5th day of August, 1993.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

  
Executive Director