

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF HARDEMAN WATER)
DISTRICT FOR A DEVIATION PURSUANT) CASE NO. 93-462
TO 807 KAR 5:066, SECTION 4(4),)
REGARDING WATER STORAGE)

O R D E R

By application received December 9, 1993, Hardeman Water District ("Hardeman Water") requested a deviation from Commission Regulation 807 KAR 5:066, Section 4(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Hardeman Water states in its application that its average daily water usage, including unaccounted-for water, is approximately 83,000 gallons, and that its current water storage capacity is 50,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Hardeman Water is not in compliance with Commission Regulation 807 KAR 5:066, Section 4(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Hardeman Water should be given until January 1, 1999 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 4(4).


IT IS THEREFORE ORDERED that:

1. Hardeman Water be and it hereby is given until January 1, 1999 to comply with the provisions of 807 KAR 5:066, Section 4(4).


2. Hardeman Water shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 1999.

Done at Frankfort, Kentucky, this 27th day of January, 1994.


PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:



Executive Director