

COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

APPLICATION OF FOX CREEK RURAL ELECTRIC )  
COOPERATIVE CORPORATION TO ADOPT A ) CASE NO. 96-244  
SAMPLE METER TESTING PLAN )

O R D E R


On July 29, 1996, the Commission issued an Order which contains a typographical error in the first paragraph. The paragraph incorrectly states that "[Fox Creek RECC] will divide its single phase meters into seven groups. . . ." It should state that the meters will be divided into four groups.


IT IS THEREFORE ORDERED, to be entered nunc pro tunc, that the first paragraph of the Commission's July 29, 1996 Order shall read as follows:


Fox Creek Rural Electric Cooperative Corporation ("Fox Creek RECC") has applied for authority to adopt a scientific sample meter testing plan for single phase meters. Under the proposed testing plan, Fox Creek RECC will test all single phase meters at least once every 25 years. It will divide its single phase meters into four groups and randomly select a minimum of 4 percent of each group for annual testing. The percentage of meters tested from each group depends upon the results from the previous year's test.

Done at Frankfort, Kentucky, this 5th day of September, 1996.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

  
Executive Director