

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF OLDHAM COUNTY WATER)
DISTRICT FOR A CERTIFICATE OF PUBLIC) CASE NO.
CONVENIENCE AND NECESSITY TO CONSTRUCT) 96-474
AND FINANCE AN IMPROVEMENTS PROJECT)

O R D E R

IT IS ORDERED that Oldham County Water District ("Oldham Water") shall file the original and 12 copies of the following information with the Commission no later than February 28, 1997, with a copy to all parties of record. Oldham Water shall furnish with each response the name of the witness who will be available for responding should a public hearing be required in this matter.

1. The construction plans for the concrete tank ("Division B") occasionally refer to specifications and detail drawings normally associated with welded steel tanks. What type of tank (concrete or steel) does Oldham Water plan to build? Do the construction plans reflect Oldham Water's current intentions? If no, provide amended plans which reflect current plans.

2. The well pumps as specified in Addendum 1 will be operating at a peak horsepower of 58.92 which is just slightly below the rated motor horsepower of 60. Provide the well pump design computations and a copy of the pump curve used in the design.

3. The geotechnical investigation provided for the site of the proposed clearwell recommends that the proposed clearwell be isolated from the existing clearwell.

The plans clearly show that the proposed clearwell will be attached to the existing clearwell. Provide an explanation for this choice of action.

4. Note 2 of the "General Notes" on the last sheet of the design plans for the 800,000 gallon tank states that the bidder will provide a foundation design with its proposal. Provide a copy of the foundation design for the 800,000 gallon tank as submitted by the low bidder.

5. The "Post Bid Project Cost Estimate and Funding Summary" prepared by James M. West and dated November 8, 1996 states that Oldham Water has voted to issue deduct change orders in the amount of approximately \$45,000. Provide the approved change orders and the dollar amounts associated with each change order.

Done at Frankfort, Kentucky, this 31st day of January, 1997.

PUBLIC SERVICE COMMISSION


For the Commission

ATTEST:


Executive Director