

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WHITLEY COUNTY)
WATER DISTRICT TO DEVIATE FROM THE) CASE NO. 96-594
REQUIREMENT OF 807 KAR 5:066, SECTION)
4(4), REGARDING WATER STORAGE)

ORDER


By application received December 11, 1996, Whitley County Water District ("Whitley Water") requested permission to deviate from 807 KAR 5:066, Section 4(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Whitley Water states in its application that its average daily water usage, including unaccounted-for water, is approximately 313,000 gallons, and its current water storage capacity is 314,000 gallons.


The Commission, having reviewed the application and being otherwise sufficiently advised, finds that Whitley Water is in compliance with 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that this case is dismissed.


Done at Frankfort, Kentucky, this 6th day of January, 1997.


PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman

ATTEST:


Executive Director


Commissioner