

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF MURRAY NO. 1 WATER	)	
DISTRICT FOR A DEVIATION OF 807 KAR	)	CASE NO.
5:066, SECTION 4(4), REGARDING WATER	)	97-246
STORAGE	)	

O R D E R

On May 8, 1997, the Murray No. 1 Water District ("Murray No. 1") applied for permission to deviate from Commission regulation 807 KAR 5:006, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. By Order of July 20, 1994 in Case No. 94-247,<sup>1</sup> Murray No. 1 was required to bring its water storage facilities into compliance with Commission regulations by July 1, 1997.

Murray No. 1 subsequently filed a letter from the City of Murray Public Works and Utilities ("City of Murray") stating that it would provide Murray No. 1's needed storage for the next three years from its 4.5 million gallons of storage capacity.

The Commission, having reviewed the application and information submitted subsequent thereto, and being otherwise sufficiently advised, finds that:

---

<sup>1</sup> Case No. 94-247, The Application of Murray No. 1 Water District for a Deviation Pursuant to 807 KAR 5:066, Section 4(4), Regarding Water Storage.

1. The total water storage capacity of Murray No. 1 is approximately 50,000 gallons.
2. Murray No. 1's average daily water usage is approximately 105,000 gallons per day.
3. The City of Murray is willing to provide Murray No. 1 with the additional needed storage capacity for the next three years.


IT IS THEREFORE ORDERED that:

1. Murray No. 1 is granted permission to deviate from the provisions of 807 KAR 5:066, Section 4(4), until July 1, 2000.
2. Murray No. 1 shall take all necessary action to bring its water storage facilities into compliance with Commission regulations by July 1, 2000.

Done at Frankfort, Kentucky, this 10th day of June, 1997.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

  
Executive Director