

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF HARRISON COUNTY RURAL)
ELECTRIC COOPERATIVE CORPORATION)
FOR A CERTIFICATE OF CONVENIENCE AND) CASE NO. 98-605
NECESSITY FOR SYSTEM IMPROVEMENTS AND)
UPGRADING OF ITS DISTRIBUTION SYSTEM)

O R D E R

IT IS ORDERED that Harrison County Rural Electric Cooperative Corporation ("Harrison County") shall file the original and five copies of the following information with the Commission with a copy to all parties of record within 15 days from the date of this Order.

1. Has Harrison County compared actual measured voltage and the calculated voltage to determine the accuracy of the voltage drop studies?
 - a. If yes, provide the voltage readings and indicate the substation, line section, and date on which each reading was taken. If the actual reading differs from the calculated voltage by more than three volts, explain the reason for the difference.
 - b. If no, explain why a comparison is not necessary.

Done at Frankfort, Kentucky, this 22nd day of April, 1999.

By the Commission

ATTEST:

Executive Director