

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

IN THE MATTER OF THE APPLICATION OF)	
WEST MCCRACKEN COUNTY WATER DISTRICT)	
FOR A DEVIATION FROM THE REQUIREMENTS)	CASE NO.
OF 807 KAR 5:066, SECTION 4(4), REGARDING)	99-420
WATER STORAGE)	

O R D E R

On October 8, 1999, West McCracken County Water District (West McCracken W. D.) applied for permission to deviate from Commission regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. West McCracken W. D. states in its application that funding for a 500,000 gallon elevated water storage tank has been accepted with construction to begin on or about July 1, 2000.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. West McCracken W. D. is not in compliance with Commission regulation 807 KAR 5:066, Section 4(4).
2. Because of the time needed to plan, finance, rebid, and construct water storage facilities, West McCracken W. D. should be given until July 1, 2005 to comply with 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. West McCracken W. D. is given until July 1, 2005 to comply with the provisions of 807 KAR 5:066, Section 4(4).

2. West McCracken W. D. shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to or by July 1, 2005.

Done at Frankfort, Kentucky, this 8th day of November, 1999.

By the Commission

ATTEST:

Executive Director