

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF KENERGY CORPORATION FOR A) CASE NO.
CERTIFICATE OF CONVENIENCE AND NECESSITY) 2000-032

O R D E R

IT IS ORDERED that Kenergy Corp. ("Kenergy") shall file the original and five copies of the following information with the Commission with a copy to all parties of record within 21 days from the date of this Order.

1. Provide two copies of the following voltage drop studies based on:
 - a. Existing loads using existing system circuitry.
 - b. Projected 2001 peak load using existing system circuitry.
 - c. Projected 2001 peak load using proposed system circuitry.
2. Has Kenergy compared actual measured voltage and the calculated voltage to determine the accuracy of the voltage drop studies?
 - a. If yes, provide the voltage reading and indicate the substation, line section, and date on which each reading was taken. If the actual reading differs from the calculated voltage by more than two volts, explain the reason for the difference.
 - b. If no, explain why a comparison is not necessary.

Done at Frankfort, Kentucky, this 24th day of March, 2000.

By the Commission

ATTEST:



Executive Director