

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF MCKINNEY WATER)	CASE NO.
DISTRICT TO DEVIATE FROM THE)	2009-00116
REQUIREMENTS OF 807 KAR 5:066, SECTION)	
4(4), REGARDING WATER STORAGE)	

O R D E R

On March 18, 2009, McKinney Water District ("McKinney District") applied for permission to deviate from 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. McKinney District states in its application that its average daily water usage, including unaccounted-for water, is approximately 277,470 gallons and that its current water storage capacity is 300,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that McKinney District currently has water storage capacity of one day's supply of its average daily usage and it therefore is in compliance with 807 KAR 5:066, Section 4(4).


IT IS THEREFORE ORDERED that:

1. McKinney District's request to deviate from 807 KAR 5:066, Section 4(4), is denied as moot.
2. McKinney District shall monitor its average daily water usage, including unaccounted-for water, as reflected in its annual report, and shall request a deviation if and when it exceeds its storage capacity.

By the Commission

ENTERED
JUL 17 2009 *M*
KENTUCKY PUBLIC
SERVICE COMMISSION

ATTEST:



Executive Director

Case No. 2009-00116

Mr. Bob Maples
Chairman
McKinney Water District
P. O. Box 7
McKinney, KY 40448