

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

APPLICATION OF BEECH GROVE WATER SYSTEM,)	CASE NO.
INC. FOR WATER STORAGE REQUIREMENT)	2009-00468
DEVIATION)	

O R D E R


On November 30, 2009, the Beech Grove Water System, Inc. ("Beech Grove Water") applied for permission to deviate from 807 KAR 5:066, Section 4(4), Storage, which requires that each utility maintain minimum water storage capacity equal to the average daily usage. Beech Grove Water states in its application that its average daily consumption, including all water sold, utility water usage, and unaccounted-for water, is approximately 145,717 gallons. Its current water storage capacity is 100,000 gallons. The Henderson Water Utility, one of Beech Grove Water's current water suppliers, has agreed that, in the event of emergency need, it will supply all water that is non-allocated to its own customer base. The West Daviess County Water District, the second of Beech Grove Water's current suppliers, has agreed to supply an additional 50,000 gallons per day and has sufficient storage to supply its own customer base. The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Beech Grove Water is not in compliance with 807 KAR 5:066, Section 4(4).
2. Because of the time needed to plan, finance, and construct water storage facilities, Beech Grove Water should be given until November 30, 2014 to comply with 807 KAR 5:066, Section 4(4).


IT IS THEREFORE ORDERED that:

1. Beech Grove Water is given until November 30, 2014 to comply with the provisions of 807 KAR 5:066, Section 4(4).
2. Beech Grove Water shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to November 30, 2014.

By the Commission



ATTEST:



Executive Director

Bernadine Edwards
Treasurer
Beech Grove Water System, Inc.
P. O. Box 118
Beech Grove, KY 42322-0118