

RECEIVED

AUG 19 2005

PUBLIC SERVICE
COMMISSION

Columbia Gas[®]
of Kentucky

A NiSource Company

P.O. Box 14241
2001 Mercer Road
Lexington, KY 40512-4241

August 19, 2005

Ms. Beth A. O'Donnell, Executive Director
Public Service Commission of Kentucky
211 Sower Boulevard
P.O. Box 615
Frankfort, Kentucky 40602

Re: **PSC Case No. 2005-00239**

Dear Ms. O'Donnell,

On August 12, 2005, the Commission's Staff docketed in the above case a Memorandum dated August 11, 2005 for Informal Conference of July 27, 2005. The cover letter with the Memorandum stated that any comments regarding the contents of the Memorandum should be submitted to the Commission. Columbia Gas of Kentucky, Inc. ("Columbia") hereby submits one correction to the Memorandum.

The second sentence of the last full paragraph of the Memorandum states, "Columbia also confirmed that a regulating pressure station will be installed to reduce the pressure at the DE pipeline to its MAOP of 720 psig." This is not factually correct. A pressure regulating station will not be installed to reduce the MAOP to 720 psig because a pressure regulating station already exists that reduces the pressure to Line DE to 720 psig MAOP. With the inclusion of this single correction, Columbia concurs that the Memorandum accurately reflects the discussions that occurred during the Informal Conference.

Please call me at (614) 460-4648 should you have any questions about this matter.

Very truly yours,

Stephen B. Seiple (jmc)

Stephen B. Seiple
Lead Counsel

Enclosures

cc: Richard S. Taylor