

October 24, 2005

Ms. Beth O'Donnell  
Executive Director  
Kentucky Public Service Commission  
211 Sower Boulevard  
P. O. Box 615  
Frankfort, KY 40602

RECEIVED

OCT 25 2005

PUBLIC SERVICE  
COMMISSION

**RE: Case No. 2005-00239**

Dear Ms. O'Donnell:

As part of the Commission's Order issued on September 20, 2005, in the above referenced case, Columbia Gas of Kentucky, Inc. ("Columbia") is required to obtain Commission approval of any deviations or additions to the construction plan approved by the Commission in the Order. By this letter, Columbia seeks Commission approval for the following changes to the construction plan previously authorized by the Commission. Revised construction drawings are attached.

A new valve (now shown as valve #1) is planned near the existing Turner Station. This valve was added to provide more flexibility to tie-in the DE extension to the existing DE line and to eliminate an existing gate valve on the very end of the existing DE line. Previously, valve #1 was referred to as an existing valve near the Toyota plant – this valve will remain in place. The distance between the existing valve near Toyota and the new valve #1 is about 5,400 feet.

The number of valves for the crossings of the railroad has been increased from three to four and the valves' placements have been changed so that there are two valves on either side of each crossing. These changes were made to match the railroads' requirements.

A valve near the Elkhorn Creek has been eliminated; however, the valve spacing requirement for a Class 4 location is still satisfied.

If you have questions, please do not hesitate to contact Judy Cooper at 859-288-0242.

Sincerely,

*Stephen B. Seiple (gmc)*

Stephen B. Seiple  
Lead Counsel

cc: Hon. Anita Mitchell

Stanley J. Sagun, Assistant General Counsel  
Stephen B. Seiple, Lead Counsel  
200 Civic Center Drive  
P.O. Box 117  
Columbus, Ohio 43216-0117  
Telephone: (614) 460-4648  
Fax: (614) 460-6986  
Email: [sseiple@nisource.com](mailto:sseiple@nisource.com)

Richard S. Taylor  
225 Capital Avenue  
Frankfort, Kentucky 40601  
Telephone: (502) 223-8967  
Fax: (502): 226-6383